

Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2247

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Hickory Heights

Address: 118 Hickory Heights Dr.

Bridgeville, PA 15017

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/16/25

Time: 1:20 PM Method: Grab

Sample Final Analysis

Date: 6/19/25 Time: 10:00 AM

Time: 10:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	6/16/25	1:20 PM	AF	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/16/25	1:20 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	1:20 PM	AF	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2247

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Hickory Heights

Address: 118 Hickory Heights Dr.

Bridgeville, PA 15017

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/16/25

Time: 1:20 PM Method: Grab

Sample Final Analysis

Date: 6/19/25 Time: 10:00 AM

Time: 10:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	6/16/25	1:20 PM	AF	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/16/25	1:20 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	1:20 PM	AF	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor