



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-1**

**Lab# 102**

**Customer**

Facility Name: *Fairfield Inn & Suites*

Address: *1438 Brodhead Rd.  
Monaca, PA 15061*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *12/15/25*

Time: *4:03 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *12/18/25*

Time: *12:30 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/16/25	12:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/16/25	12:00 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/15/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/15/25	4:03 PM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/15/25	4:03 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/15/25	4:03 PM	SL	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)