



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2140**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Date: 8/5/25*  
*Time: 11:11 AM*  
*Method: Grab*

**Sample Final Analysis**

*Date: 8/8/25*  
*Time: 8:30 AM*  
*Analyst: AS*

*Facility Name: Cranberry Woods*  
*Address: 1000 Creekview Cir.*  
*Cranberry Twp., PA 16066*

*Matrix: Recreational Water*  
*Source Type: Pool*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	1:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	1:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:40 PM	AS	SM 9215B
Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/5/25	11:11 AM	ZR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/5/25	11:11 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	11:11 AM	ZR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2140**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Date: 8/5/25*  
*Time: 11:11 AM*  
*Method: Grab*

**Sample Final Analysis**

*Date: 8/8/25*  
*Time: 8:30 AM*  
*Analyst: AS*

*Facility Name: Cranberry Woods*  
*Address: 1000 Creekview Cir.*  
*Cranberry Twp., PA 16066*

*Matrix: Recreational Water*  
*Source Type: Pool*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	1:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	1:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:40 PM	AS	SM 9215B
Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/5/25	11:11 AM	ZR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/5/25	11:11 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	11:11 AM	ZR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor