

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

L - 13

Lab# 2349

Customer				Sample Collection					
Facility Name:	Meadowink	Swim Club	Date: Time:		7/8/25 7:54 AM				
Address:	4220 Bullto	wn Rd		Method:	Grab				
	Murrysville	PA 15668							
			Sample Final Analysis						
Matrix:	Recreation	al Water		Date:	7/11/2	5			
			Time:		9:00 AM				
Source Type:	e Type: Shallow End			Analyst:	AS	3			
Accredited Analysis	Results	Reporting limit	Incubation	on Date/Time	Analyst	Method			
Escherichia Coli	Absent	Absent	7/9/25	9:00 AM	FB	SM 92			

						i
Escherichia Coli:	Absent	Absent	7/9/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	3:28 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
рН:	7.4 SU	7.2 - 7.8 SU	7/8/25	7:54 AM	EH	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/8/25	7:54 AM	EH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	7:54 AM	EH	Visual	

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

L - 13

Lab# 2349

Customer				Sample Collection					
Facility Name:	Meadowink	Swim Club	Date: Time:		7/8/25 7:54 AM				
Address:	4220 Bullto	wn Rd		Method:	Grab				
	Murrysville	PA 15668							
			Sample Final Analysis						
Matrix:	Recreation	al Water		Date:	7/11/2	5			
			Time:		9:00 AM				
Source Type:	e Type: Shallow End			Analyst:	AS	3			
Accredited Analysis	Results	Reporting limit	Incubation	on Date/Time	Analyst	Method			
Escherichia Coli	Absent	Absent	7/9/25	9:00 AM	FB	SM 92			

						i
Escherichia Coli:	Absent	Absent	7/9/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	3:28 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
рН:	7.4 SU	7.2 - 7.8 SU	7/8/25	7:54 AM	EH	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/8/25	7:54 AM	EH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	7:54 AM	EH	Visual	

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)