

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

W-11

Lab# 411

Customer Sample Collection

Facility Name: Fairfield Inn Time:

1004 Sutherland Dr. Address: Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Spa

5/27/25 Date: 10:00 AM Method: Grab

Sample Final Analysis

Date: 5/30/25 Time: 9:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	2:55 PM	АН	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/28/25	11:30 AM	АН	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
рН:	7.4 SU	7.2 - 7.8 SU	5/27/25	10:00 AM	VH	DPD	
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	5/27/25	10:00 AM	VH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	10:00 AM	VH	Visual	

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

W-11

Lab# 411

Customer Sample Collection

Facility Name: Fairfield Inn Time:

1004 Sutherland Dr. Address: Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Spa

5/27/25 Date: 10:00 AM Method: Grab

Sample Final Analysis

Date: 5/30/25 Time: 9:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	2:55 PM	АН	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/28/25	11:30 AM	АН	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
рН:	7.4 SU	7.2 - 7.8 SU	5/27/25	10:00 AM	VH	DPD	
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	5/27/25	10:00 AM	VH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	10:00 AM	VH	Visual	

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor