



Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665

Lab ID No. 02-04041

SERVICE

Lab# 2040

## Laboratory Analysis Report

### Customer

Facility Name: Berkshire Estate  
Address: 6000 Middle Field Dr.  
McDonald, PA 15057

Matrix: Recreational Water

Source Type: Pool

### Sample Collection

Date: 8/26/25  
Time: 7:54 AM  
Method: Grab

### Sample Final Analysis

Date: 8/29/25  
Time: 10:30 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/25	11:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/25	11:00 AM	AS	SM 9222B
Standard plate count:	300/ml	200/ml	8/26/25	4:55 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/26/25	7:54 AM	AMH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/26/25	7:54 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/25	7:54 AM	AMH	Visual

### Sample comments

( When exceeding reporting limit pool or spa is unfit)

Anaë Smith