



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2178

Customer

Facility Name: *Estates of Forest Grove*

Address: *1500 Meerscham Ln.
Kennedy, PA 15108*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/11/25*

Time: *7:45 AM*

Method: *Grab*

Sample Final Analysis

Date: *6/13/25*

Time: *3:00 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	5:30 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	5:30 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/11/25	4:40 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/11/25	7:45 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/11/25	7:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25	7:45 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2178

Customer

Facility Name: *Estates of Forest Grove*

Address: *1500 Meerschau Ln.
Kennedy, PA 15108*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/11/25*

Time: *7:45 AM*

Method: *Grab*

Sample Final Analysis

Date: *6/13/25*

Time: *3:00 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	5:30 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	5:30 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/11/25	4:40 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/11/25	7:45 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/11/25	7:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25	7:45 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor