

## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

Lab ID #

Lab# 2710

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Evergreen Apt. Sample Collection
Date: 6/23

 Evergreen Apt.
 Date:
 6/23/25

 Time:
 7:05 AM

Address: 3730 Evergreen Dr. Method: Grab

Monroeville, PA 15146

Matrix: Recreational Water Date: 6/26/25
Time: 9:00 AM

Source Type: Pool Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	9:15 AM	EB	SM 9222B
Standard plate count:	200/ml	200/ml	6/23/25	3:03 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/23/25	7:05 AM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/23/25	7:05 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	7:05 AM	EH	Visual

## Sample comments

andre Smith

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Sample Final Analysis



## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

Lab ID #

Lab# 2710

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Evergreen Apt. Sample Collection
Date: 6/23

 Evergreen Apt.
 Date:
 6/23/25

 Time:
 7:05 AM

Address: 3730 Evergreen Dr. Method: Grab

Monroeville, PA 15146

Matrix: Recreational Water Date: 6/26/25
Time: 9:00 AM

Source Type: Pool Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	9:15 AM	EB	SM 9222B
Standard plate count:	200/ml	200/ml	6/23/25	3:03 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/23/25	7:05 AM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/23/25	7:05 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	7:05 AM	EH	Visual

## Sample comments

andre Smith

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Sample Final Analysis