

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

S-14

Lab ID No. 02-04041

Lab# 2355

Customer

Montclair Estates Facility Name:

1200 Sherbrook Drive Address:

Pittsburgh, PA 15241

Matrix: Recreational Water

Source Type: Pool Sample Collection

Date:

6/24/25 12:23 PM

Time: Method:

Grab

Sample Final Analysis

Date:

6/27/25

Time: Analyst: 9:20 AM AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	12:00 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	12:00 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/24/25	12:23 PM	AF	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/24/25	12:23 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	12:23 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

S-14

Lab ID No. 02-04041

Lab# 2355

Customer

Montclair Estates Facility Name:

1200 Sherbrook Drive Address:

Pittsburgh, PA 15241

Matrix: Recreational Water

Source Type: Pool Sample Collection

Date:

6/24/25 12:23 PM

Time: Method:

Grab

Sample Final Analysis

Date:

6/27/25

Time: Analyst: 9:20 AM AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	12:00 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	12:00 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/24/25	12:23 PM	AF	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/24/25	12:23 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	12:23 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith