



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 338

Customer

Facility Name: White Oak Village
Address: 152 Royal Oak Drive
McKeesport, PA 15131

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 1/12/26
Time: 2:33 PM
Method: Grab

Sample Final Analysis

Date: 1/15/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/13/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/13/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/12/26	4:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	1/12/26	2:33 PM	JC	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	1/12/26	2:33 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/12/26	2:33 PM	JC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)