



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-14

Lab# 470

Customer

Facility Name: Hampton Inn
Address: 62 Pine Ridge Rd.
Blairsville, PA 15717

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/9/25
Time: 2:04 PM
Method: Grab

Sample Final Analysis

Date: 7/12/25
Time: 8:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/9/25 | 4:30 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/9/25 | 4:30 PM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/9/25 | 4:15 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 7/9/25 | 2:04 PM | SL | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 7/9/25 | 2:04 PM | SL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/9/25 | 2:04 PM | SL | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andrea Smith



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-14

Lab# 470

Customer

Facility Name: Hampton Inn
Address: 62 Pine Ridge Rd.
Blairsville, PA 15717

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/9/25
Time: 2:04 PM
Method: Grab

Sample Final Analysis

Date: 7/12/25
Time: 8:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/9/25 | 4:30 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/9/25 | 4:30 PM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/9/25 | 4:15 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 7/9/25 | 2:04 PM | SL | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 7/9/25 | 2:04 PM | SL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/9/25 | 2:04 PM | SL | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andrea Smith