

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2097

Customer

Facility Name: *Chartiers Valley C.C.*

Sample Collection

Date: 6/25/25

Address: *601 Baldwin Road
Pittsburgh, PA 15205*

Time: 9:30 AM

Method: Grab

Matrix: *Recreational Water*

Sample Final Analysis

Date: 6/27/25

Source Type: *Deep End*

Time: 4:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/25/25	3:40 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	3:40 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/25/25	2:44 PM	EB	SM 9215B


Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.0 SU	7.2 - 7.8 SU	6/25/25	9:30 AM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/25/25	9:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/25/25	9:30 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2097

Customer

Facility Name: *Chartiers Valley C.C.*

Sample Collection

Date: 6/25/25

Address: *601 Baldwin Road
Pittsburgh, PA 15205*

Time: 9:30 AM

Method: Grab

Matrix: *Recreational Water*

Sample Final Analysis

Date: 6/27/25

Source Type: *Deep End*

Time: 4:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/25/25	3:40 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	3:40 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/25/25	2:44 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.0 SU	7.2 - 7.8 SU	6/25/25	9:30 AM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/25/25	9:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/25/25	9:30 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor