



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 305

Customer

Facility Name: University of Pittsburgh

Address: 3501 Allequippa St.
Pittsburgh, PA 15260

Matrix: Recreational Water

Source Type: Lg Pool Middle 2

Sample Collection

Date: 12/10/25

Time: 2:13 PM

Method: Grab

Sample Final Analysis

Date: 12/12/25

Time: 4:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/10/25	4:10 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/10/25	4:10 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	12/10/25	4:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/10/25	2:13 PM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/10/25	2:13 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/10/25	2:13 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor