



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-12**

**Lab# 2399**

**Customer**

**Facility Name:** *Pennsbury Village*  
**Address:** *1039 Pennsbury Blvd.*  
*Pittsburgh, PA 15205*

**Sample Collection**

**Date:** *6/11/25*  
**Time:** *10:00 AM*  
**Method:** *Grab*

**Sample Final Analysis**

**Date:** *6/13/25*  
**Time:** *3:00 PM*  
**Analyst:** *AS*

**Matrix:** *Recreational Water*  
**Source Type:** *Shallow End*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	3:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	3:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/11/25	3:33 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/11/25	10:00 AM	VH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/11/25	10:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25	10:00 AM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-12**

**Lab# 2399**

**Customer**

Facility Name: *Pennsbury Village*  
  
Address: *1039 Pennsbury Blvd.*  
*Pittsburgh, PA 15205*

**Sample Collection**

Date: *6/11/25*  
Time: *10:00 AM*  
Method: *Grab*

Matrix: *Recreational Water*  
  
Source Type: *Shallow End*

**Sample Final Analysis**

Date: *6/13/25*  
Time: *3:00 PM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	3:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	3:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/11/25	3:33 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	6/11/25	10:00 AM	VH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/11/25	10:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25	10:00 AM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor