1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2443

Customer			*Sample Collection*	
Facility Name:	*Riverview*		*Date:*	*8/4/25*
			Time:	2:00 PM
Address:	*400 Riverview Ave.*		*Method:*	*Grab*
	Pittsburgh, PA 15214			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*8/7/25*
			Time:	*11:20 AM*
Source Type:	*Deep End*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	10:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	10:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	4:21 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	8/4/25	2:00 PM	WB	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/4/25	2:00 PM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	2:00 PM	WB	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2443

Customer

		Sample Collection	
Facility Name:	*Riverview*	*Date:*	*8/4/25*
		Time:	2:00 PM
Address:	*400 Riverview Ave.*	*Method:*	*Grab*
	Pittsburgh, PA 15214		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*8/7/25*
		Time:	*11:20 AM*
Source Type:	*Deep End*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	10:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	10:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	4:21 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	8/4/25	2:00 PM	WB	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/4/25	2:00 PM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	2:00 PM	WB	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor