



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2523

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Thorn Run Apts*

Sample Collection

Date: 8/18/25

Address: 700 Lee Drive
Coraopolis, PA 15108

Time: 11:45 AM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 8/21/25

Source Type: Pool

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/19/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/19/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/18/25	2:42 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	8/18/25	11:45 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/18/25	11:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/18/25	11:45 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Anne Smith

Anne Smith, Lead Supervisor