



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 296

Customer

Facility Name: Steel Valley High School

Address: 3113 Main Street
Munhall, PA 15120

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 12/1/25

Time: 8:55 AM

Method: Grab

Sample Final Analysis

Date: 12/4/25

Time: 11:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/2/25	10:55 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/2/25	10:55 AM	AS	SM 9222B
Standard plate count:	570/ml	200/ml	12/1/25	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.0 SU	7.2 - 7.8 SU	12/1/25	8:55 AM	SH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/1/25	8:55 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/1/25	8:55 AM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor