



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 178

Customer

Facility Name: Hyatt Place
Address: 260 North Shore Dr.
Pittsburgh, PA 15212

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/30/25
Time: 12:45 PM
Method: Grab

Sample Final Analysis

Date: 1/2/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/31/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/31/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/25	4:54 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/30/25 12:45 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/30/25 12:45 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/30/25 12:45 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor