Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 2347

Customer			_Sample Collection_	
Facility Name:	*Meadowbrook Apt*		*Date:*	*8/11/25*
			Time:	*1:15 PM*
Address:	*13 Meadow Brook Lane*		*Method:*	*Grab*
	Butler, PA 16001			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*8/14/25*
			Time:	*9:00 AM*
Source Type:	*Pool*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	10:00 AM	EB	SM 9222B
Standard plate count:	22/ml	200/ml	8/11/25	5:20 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/11/25	1:15 PM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/11/25	1:15 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	1:15 PM	BH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

B & R Pools and Swim Shop

Customer
Facility Name:	Meadowbrook Apt
Address:	13 Meadow Brook Lane Butler, PA 16001
Matrix:	Recreational Water
Source Type:	Pool

Sample Collection
Date:	8/11/25
Time:	1:15 PM
Method:	Grab

Sample Final Analysis
Date:	8/14/25
Time:	9:00 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	10:00 AM	EB	SM 9222B
Standard plate count:	22/ml	200/ml	8/11/25	5:20 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/11/25	1:15 PM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/11/25	1:15 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	1:15 PM	BH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor