



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-16**

**Lab# 2174**

**Customer**

**Facility Name:** *Elmhurst Swim Club*  
**Address:** *1 South Wilmont Ave.*  
*Washington, PA 15301*

**Sample Collection**

**Date:** *7/8/25*  
**Time:** *11:47 AM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*

**Source Type:** *Pool*

**Sample Final Analysis**

**Date:** *7/11/25*  
**Time:** *9:00 AM*  
**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	10:40 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	5:35 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/8/25	11:47 AM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/8/25	11:47 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	11:47 AM	SL	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-16**

**Lab# 2174**

**Customer**

**Facility Name:** *Elmhurst Swim Club*  
**Address:** *1 South Wilmont Ave.*  
*Washington, PA 15301*

**Sample Collection**

**Date:** *7/8/25*  
**Time:** *11:47 AM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*

**Source Type:** *Pool*

**Sample Final Analysis**

**Date:** *7/11/25*  
**Time:** *9:00 AM*  
**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	10:40 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	5:35 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/8/25	11:47 AM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/8/25	11:47 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	11:47 AM	SL	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor