



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-3**

**Lab# 166**

**Customer**

**Facility Name:** *Holiday Inn Express - Southpointe*

**Address:** *4000 Horizon Vue Drive  
Canonsburg, PA 15317*

**Matrix:** *Recreational Water*

**Source Type:** *Pool*

**Sample Collection**

**Date:** *11/24/25*

**Time:** *11:44 AM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *11/27/25*

**Time:** *10:00 AM*

**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/25/25	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/25/25	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	11/24/25	4:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	11/24/25	11:44 AM	GR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	11/24/25	11:44 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/24/25	11:44 AM	GR	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)