Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# **2611**

Customer

Facility Name:	YMCA - East Suburban
Address:	2200 Golden Mile Hwy. Plum, PA 15239
Matrix:	Recreational Water
Source Type:	Baby Pool

Sample Collection

Date:	7/8/25
Time:	9:00 AM
Method:	Grab

Sample Final Analysis

Date:	7/11/25
Time:	9:00 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	3:48 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/8/25	9:00 AM	EH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/8/25	9:00 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	9:00 AM	EH	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2611

Customer

Facility Name:	YMCA - East Suburban
Address:	2200 Golden Mile Hwy. Plum, PA 15239
Matrix:	Recreational Water
Source Type:	Baby Pool

Sample Collection

Date:	7/8/25
Time:	9:00 AM
Method:	Grab

Sample Final Analysis

Date:	7/11/25
Time:	9:00 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	3:48 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/8/25	9:00 AM	EH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/8/25	9:00 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	9:00 AM	EH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor