



Lab ID No. 02-04041

**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

**Service****Lab# 313****Customer****Facility Name:** UPMC Sports Rehab - Cranberry**Address:** 8000 Cranberry Springs Drive  
Cranberry Township, PA 16066**Matrix:** Recreational Water**Source Type:** Spa**Sample Collection****Date:** 2/3/26**Time:** 12:00 PM**Method:** Grab**Sample Final Analysis****Date:** 2/6/26**Time:** 10:30 AM**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/4/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/4/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/3/26	3:40 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	2/4/26	11:00 AM	SL	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	2/3/26	12:00 PM	RD	DPD
Chlorine:	2.6 mg/l	1.0 - 5.0 mg/l	2/3/26	12:00 PM	RD	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/3/26	12:00 PM	RD	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)