



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-13**

**Lab# 132**

**Customer**

Facility Name: Hampton Inn Uniontown

Address: 698 West Main Street  
Uniontown, Pa 15401

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 8/11/25

Time: 1:10 PM

Method: Grab

**Sample Final Analysis**

Date: 8/14/25

Time: 9:00 AM

Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 8/12/25              | 10:30 AM | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 8/12/25              | 10:30 AM | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 8/11/25              | 5:20 PM  | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 8/11/25   | 1:10 PM | SH      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 8/11/25   | 1:10 PM | SH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 8/11/25   | 1:10 PM | SH      | Visual |

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-13**

**Lab# 132**

**Customer**

Facility Name: Hampton Inn Uniontown

Address: 698 West Main Street  
Uniontown, Pa 15401

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 8/11/25

Time: 1:10 PM

Method: Grab

**Sample Final Analysis**

Date: 8/14/25

Time: 9:00 AM

Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 8/12/25              | 10:30 AM | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 8/12/25              | 10:30 AM | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 8/11/25              | 5:20 PM  | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 8/11/25   | 1:10 PM | SH      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 8/11/25   | 1:10 PM | SH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 8/11/25   | 1:10 PM | SH      | Visual |

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor