

Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2237

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Greenbriar Village

Address: 1701 Greenvalley Driv

1701 Greenvalley Drive Pittsburgh, PA 15220

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/2/25
Time: 2:25 PM
Method: Grab

Sample Final Analysis

Date: 6/5/25 Time: 9:30 AM

Analyst: 9.30 AW

Accredited Analysis Results **Reporting limit Analyst** Method **Incubation Date/Time** Escherichia Coli: 6/3/25 11:00 AM EΒ Absent Absent SM 9222G Total coliforms: 0/100mls 2/100mls 6/3/25 11:00 AM EΒ SM 9222B Standard plate count: 0/ml200/ml 6/2/25 6:30 PM SL SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/2/25	2:25 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/2/25	2:25 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	2:25 PM	CW	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2237

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Greenbriar Village

Address: 1701 Greenvalley Driv

1701 Greenvalley Drive Pittsburgh, PA 15220

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/2/25
Time: 2:25 PM
Method: Grab

Sample Final Analysis

Date: 6/5/25 Time: 9:30 AM

Analyst: 9.30 AW

Accredited Analysis Results **Reporting limit Analyst** Method **Incubation Date/Time** Escherichia Coli: 6/3/25 11:00 AM EΒ Absent Absent SM 9222G Total coliforms: 0/100mls 2/100mls 6/3/25 11:00 AM EΒ SM 9222B Standard plate count: 0/ml200/ml 6/2/25 6:30 PM SL SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/2/25	2:25 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/2/25	2:25 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	2:25 PM	CW	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor