



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**C-11**

**Lab# 2720**

**Customer**

Facility Name: *Brewer's Block*  
  
Address: *3234 Libery Ave.*  
*Pittsburgh, PA 15201*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *8/19/25*  
Time: *8:30 AM*  
Method: *Grab*

**Sample Final Analysis**

Date: *8/22/25*  
Time: *9:00 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/20/25	10:05 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/20/25	10:05 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/19/25	4:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/19/25	8:30 AM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/19/25	8:30 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/19/25	8:30 AM	LM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Anaëe Smith*