

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 414

Customer Sample Collection

2/100mls

Facility Name: Townplace Suites Airport Date: 7/22/25
Time: 10:15 AM

Address: 1006 Sutherland Dr.
Pittsburgh, PA 15205

0/100mls

Matrix: Recreational Water

Source Type: Spa

Method: Grab

Sample Final Analysis
Date: 7/25/25

Time: 10:00 AM Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	9:20 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	9:20 AM	АН	SM 9222B
Standard plate count:	5700/ml	200/ml	7/22/25	3:40 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method

7/23/25

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.4 SU	7.2 - 7.8 SU	7/22/25	10:15 AM	VH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/22/25	10:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	10:15 AM	VH	Visual

Sample comments

Fecal Streptococcus

andre Smith

12:20 PM

SL

SM 9230C

(When exceeding reporting limit pool or spa is unfit)



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 414

Customer Sample Collection

2/100mls

Facility Name: Townplace Suites Airport Date: 7/22/25
Time: 10:15 AM

Address: 1006 Sutherland Dr.
Pittsburgh, PA 15205

0/100mls

Matrix: Recreational Water

Source Type: Spa

Method: Grab

Sample Final Analysis
Date: 7/25/25

Time: 10:00 AM Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	9:20 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	9:20 AM	АН	SM 9222B
Standard plate count:	5700/ml	200/ml	7/22/25	3:40 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method

7/23/25

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.4 SU	7.2 - 7.8 SU	7/22/25	10:15 AM	VH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/22/25	10:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	10:15 AM	VH	Visual

Sample comments

Fecal Streptococcus

andre Smith

12:20 PM

SL

SM 9230C

(When exceeding reporting limit pool or spa is unfit)