



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2515

Customer

Facility Name: *Summerset at Frick Park*

Address: *1425 Parkview Blvd.
Pittsburgh, PA 15217*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *5/27/25*

Time: *10:20 AM*

Method: *Grab*

Sample Final Analysis

Date: *5/30/25*

Time: *9:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	9:15 AM	EB	SM 9222B
Standard plate count:	100/ml	200/ml	5/27/25	2:55 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/27/25	10:20 AM	MB	DPD
Chlorine:	2.2 mg/l	1.0 - 5.0 mg/l	5/27/25	10:20 AM	MB	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	10:20 AM	MB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2515

Customer

Facility Name: *Summerset at Frick Park*

Address: *1425 Parkview Blvd.
Pittsburgh, PA 15217*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *5/27/25*

Time: *10:20 AM*

Method: *Grab*

Sample Final Analysis

Date: *5/30/25*

Time: *9:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	9:15 AM	EB	SM 9222B
Standard plate count:	100/ml	200/ml	5/27/25	2:55 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/27/25	10:20 AM	MB	DPD
Chlorine:	2.2 mg/l	1.0 - 5.0 mg/l	5/27/25	10:20 AM	MB	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	10:20 AM	MB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor