

## **Dream Pools and Spas** 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

N-13

Lab# 2387

Sample Collection Customer

Facility Name: Oxford Athletic Date: 6/16/25

Time: 2:33 PM Method: Address: 100 Village Club Dr. Grab

Wexford, PA 15090

Sample Final Analysis Matrix: Recreational Water Date: 6/19/25

10:00 AM Time:

Source Type: Baby Pool Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	n Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	10:40 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	10:40 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	5:45 PM	EB	SM 9215B

Field Analysis	Results	Results Reporting limit		Date/Time		Method
pH:	8.0 SU	7.2 - 7.8 SU	6/16/25	2:33 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/16/25	2:33 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	2:33 PM	MM	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## **Dream Pools and Spas** 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

N-13

Lab# 2387

Sample Collection Customer

Facility Name: Oxford Athletic Date: 6/16/25

Time: 2:33 PM Method: Address: 100 Village Club Dr. Grab

Wexford, PA 15090

Sample Final Analysis Matrix: Recreational Water Date: 6/19/25

10:00 AM Time:

Source Type: Baby Pool Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	n Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	10:40 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	10:40 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	5:45 PM	EB	SM 9215B

Field Analysis	Results	Results Reporting limit		Date/Time		Method
pH:	8.0 SU	7.2 - 7.8 SU	6/16/25	2:33 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/16/25	2:33 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	2:33 PM	MM	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor