



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2595

Customer *American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237*

Facility Name: *The View @North Hills*

Sample Collection

Date: 5/28/25

Time: 11:11 AM

Method: Grab

Address: *1000 Johanna Drive
Pittsburgh, PA 15237*

Sample Final Analysis

Date: 5/31/25

Time: 9:30 AM

Analyst: AS

Matrix: *Recreational Water*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	5/29/25	11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	6:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	5/28/25	11:11 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/28/25	11:11 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	11:11 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2595

Customer *American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237*

Facility Name: *The View @North Hills*

Sample Collection

Date: 5/28/25

Time: 11:11 AM

Method: Grab

Address: *1000 Johanna Drive
Pittsburgh, PA 15237*

Sample Final Analysis

Date: 5/31/25

Time: 9:30 AM

Analyst: AS

Matrix: *Recreational Water*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	5/29/25	11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	6:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	5/28/25	11:11 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/28/25	11:11 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	11:11 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor