



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-13

Lab# 2387

Customer

Facility Name: Oxford Athletic
Address: 100 Village Club Dr.
Wexford, PA 15090

Sample Collection

Date: 7/14/25
Time: 2:59 PM
Method: Grab

Sample Final Analysis

Date: 7/17/25
Time: 8:30 AM
Analyst: AS

Matrix: Recreational Water
Source Type: Baby Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	11:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	11:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	5:30 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/14/25	2:59 PM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/14/25	2:59 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	2:59 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-13

Lab# 2387

Customer

Facility Name: Oxford Athletic
Address: 100 Village Club Dr.
Wexford, PA 15090

Sample Collection

Date: 7/14/25
Time: 2:59 PM
Method: Grab

Sample Final Analysis

Date: 7/17/25
Time: 8:30 AM
Analyst: AS

Matrix: Recreational Water
Source Type: Baby Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	11:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	11:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	5:30 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/14/25	2:59 PM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/14/25	2:59 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	2:59 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor