



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-2**

**Lab# 175**

**Customer**

Facility Name: Hyatt House  
Address: 2795 South Water St.  
Pittsburgh, PA 15603

**Sample Collection**

Date: 1/13/26  
Time: 2:20 PM  
Method: Grab

**Sample Final Analysis**

Date: 1/16/26  
Time: 10:30 AM  
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/14/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/14/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/13/26	4:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	1/13/26	2:20 PM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	1/13/26	2:20 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/13/26	2:20 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor