



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 029

Customer

Facility Name: *Fairfield Inn*

Address: *451 Racetrack Rd.*
Washington, PA 15301

Sample Collection

Date: *12/1/25*
Time: *10:08 AM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *12/4/25*
Time: *10:00 AM*
Analyst: *AS*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/2/25	9:35 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/2/25	9:35 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/1/25	4:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/1/25	10:08 AM	GR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/1/25	10:08 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/1/25	10:08 AM	GR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)