



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 387

Customer		Sample Collection				
Facility Name:	Residence Inn Cranberry	Date:	8/4/25			
Address:	1308 Freedom Rd. Cranberry, PA 16066	Time:	11:12 AM			
Matrix:		Method:	Grab			
Source Type:		Sample Final Analysis				
		Date:	8/7/25			
		Time:	11:20 AM			
		Analyst:	#REF!			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/5/25	10:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	10:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	4:21 PM	AH	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Fecal Streptococcus	0/100mls	2/100mls	8/5/25	1:45 PM	AH	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	8/4/25	11:12 AM	ZR	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	8/4/25	11:12 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	11:12 AM	ZR	Visual

Sample comments

Anne Smith

(When exceeding reporting limit pool or spa is unfit)



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 387

Customer		Sample Collection				
Facility Name:	Residence Inn Cranberry	Date:	8/4/25			
Address:	1308 Freedom Rd. Cranberry, PA 16066	Time:	11:12 AM			
Matrix:		Method:	Grab			
Source Type:		Sample Final Analysis				
		Date:	8/7/25			
		Time:	11:20 AM			
		Analyst:	#REF!			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/5/25	10:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	10:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	4:21 PM	AH	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Fecal Streptococcus	0/100mls	2/100mls	8/5/25	1:45 PM	AH	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	8/4/25	11:12 AM	ZR	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	8/4/25	11:12 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	11:12 AM	ZR	Visual

Sample comments

Anne Smith

(When exceeding reporting limit pool or spa is unfit)