



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E-2**

**Lab# 441**

**Customer**

Facility Name: Hampton Inn  
Address: N. Rachel Dr  
New Stanton, PA 15672

**Sample Collection**

Date: 10/27/25  
Time: 9:17 AM  
Method: Grab

**Sample Final Analysis**

Date: 10/30/25  
Time: 10:00 AM  
Analyst: AS

Matrix: Recreational Water  
Source Type: Pool

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 10/28/25             | 9:30 AM | JC      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 10/28/25             | 9:30 AM | JC      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 10/27/25             | 5:15 PM | AS      | SM 9215B |

| Field Analysis | Results   | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|-----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.6 SU    | 7.2 - 7.8 SU    | 10/27/25  | 9:17 AM | JC      | DPD    |
| Chlorine:      | 10.0 mg/l | 1.0 - 5.0 mg/l  | 10/27/25  | 9:17 AM | JC      | DPD    |
| Turbidity:     | 1 NTU     | 1 - 2 NTU       | 10/27/25  | 9:17 AM | JC      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor