

## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

**APM 2** 

Lab# 2149

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Deauville Park Apts

Address: 540 Deauville Drive

Monroeville, PA 15146

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 5/27/25

Time: 3:27 PM Method: Grab

Sample Final Analysis

Date: 5/30/25 Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method		
Escherichia Coli:	Absent	Absent	5/28/25	10:15 AM	EB	SM 9222G		
Total coliforms:	0/100mls	2/100mls	5/28/25	10:15 AM	EB	SM 9222B		
Standard plate count:	0/ml	200/ml	5/27/25	7:00 PM	AS	SM 9215B		

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	5/27/25	3:27 PM	EH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	5/27/25	3:27 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	3:27 PM	EH	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

**APM 2** 

Lab# 2149

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Deauville Park Apts

Address: 540 Deauville Drive

Monroeville, PA 15146

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 5/27/25

Time: 3:27 PM Method: Grab

Sample Final Analysis

Date: 5/30/25 Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method		
Escherichia Coli:	Absent	Absent	5/28/25	10:15 AM	EB	SM 9222G		
Total coliforms:	0/100mls	2/100mls	5/28/25	10:15 AM	EB	SM 9222B		
Standard plate count:	0/ml	200/ml	5/27/25	7:00 PM	AS	SM 9215B		

Field Analysis	Results	Reporting limit	Date/Time		porting limit Date/Time		Analyst	Analyst Method	
pH:	8.0 SU	7.2 - 7.8 SU	5/27/25	3:27 PM	EH	DPD			
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	5/27/25	3:27 PM	EH	DPD			
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	3:27 PM	EH	Visual			

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor