Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer

Facility Name:	*Meeder Flats*
Address:	*1000 Strand Road*
	Cranberry, PA 16066
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*6/30/25*
Time:	12:55 PM
Method:	*Grab*

Sample Final Analysis

Date:	*7/3/25*
Time:	*9:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:00 AM	EB	SM 9222B
Standard plate count:	5700/ml	200/ml	6/30/25	3:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/30/25	12:55 PM	ZR	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/30/25	12:55 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	12:55 PM	ZR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer				*Sample Collection*	
Facility Name:	*Meeder Flats*			*Date:*	*6/30/25*
				Time:	12:55 PM
Address:	*1000 Strand Road*			*Method:*	*Grab*
	Cranberry, PA 16066				
				Sample Final Analysis	
Matrix:	*Recreational Water*			*Date:*	*7/3/25*
				Time:	*9:30 AM*
Source Type:	*Pool*			*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:00 AM	EB	SM 9222B
Standard plate count:	5700/ml	200/ml	6/30/25	3:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/30/25	12:55 PM	ZR	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/30/25	12:55 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	12:55 PM	ZR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)