



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 296

Customer

Facility Name: Steel Valley High School

Address: 3113 Main Street
Munhall, PA 15120

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 9/29/25

Time: 9:10 AM

Method: Grab

Sample Final Analysis

Date: 10/2/25

Time: 10:30 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 9/30/25 | 10:10 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 9/30/25 | 10:10 AM | SL | SM 9222B |
| Standard plate count: | 570/ml | 200/ml | 9/29/25 | 5:25 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|---------|--------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 9/29/25 | 9:10 AM | SH | DPD |
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 9/29/25 | 9:10 AM | SH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 9/29/25 | 9:10 AM | SH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor