



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

LCP

Lab# 2381

Customer

Facility Name: O'Hara Woods Club
Address: 100 O'Hara Woods Dr.
Pittsburgh, PA 15238

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 9/4/25
Time: 8:39 AM
Method: Grab

Sample Final Analysis

Date: 9/6/25
Time: 2:00 PM
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/4/25	4:30 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/4/25	4:30 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	9/4/25	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/4/25	8:39 AM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	9/4/25	8:39 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/4/25	8:39 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor