



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-12**

**Lab# 2495**

**Customer**

Facility Name: South Hills Country Club

Address: 4305 Brownsville Road  
Pittsburgh, PA 15236

Matrix: Recreational Water

Source Type: Shallow End

**Sample Collection**

Date: 6/23/25

Time: 3:00 PM

Method: Grab

**Sample Final Analysis**

Date: 6/26/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	11:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	11:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	6:10 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/23/25	3:00 PM	DW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/23/25	3:00 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	3:00 PM	DW	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-12**

**Lab# 2495**

**Customer**

Facility Name: South Hills Country Club

Address: 4305 Brownsville Road  
Pittsburgh, PA 15236

Matrix: Recreational Water

Source Type: Shallow End

**Sample Collection**

Date: 6/23/25

Time: 3:00 PM

Method: Grab

**Sample Final Analysis**

Date: 6/26/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	11:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	11:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	6:10 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/23/25	3:00 PM	DW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/23/25	3:00 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	3:00 PM	DW	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor