



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-12**

**Lab# 2671**

**Customer**

**Facility Name:** Summer Seat  
**Address:** 114 Gateway Dr.  
Pittsburgh, PA 15237

**Sample Collection**

**Date:** 7/30/25  
**Time:** 11:27 AM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Spa

**Sample Final Analysis**

**Date:** 8/1/25  
**Time:** 3:30 PM  
**Analyst:** 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/30/25	4:55 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	4:55 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/30/25	4:50 PM	EB	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/30/25	5:40 PM	SL	SM 9230C
---------------------	----------	----------	---------	---------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	7/30/25	11:27 AM	MM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/30/25	11:27 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/30/25	11:27 AM	MM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-12**

**Lab# 2671**

**Customer**

**Facility Name:** Summer Seat  
**Address:** 114 Gateway Dr.  
Pittsburgh, PA 15237

**Sample Collection**

**Date:** 7/30/25  
**Time:** 11:27 AM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Spa

**Sample Final Analysis**

**Date:** 8/1/25  
**Time:** 3:30 PM  
**Analyst:** 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/30/25	4:55 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	4:55 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/30/25	4:50 PM	EB	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/30/25	5:40 PM	SL	SM 9230C
---------------------	----------	----------	---------	---------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	7/30/25	11:27 AM	MM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/30/25	11:27 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/30/25	11:27 AM	MM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor