



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 117

Customer

Facility Name: *Hampton Inn*
Address: *1247 Smallman St.
Pittsburgh, PA 15222*
Matrix: *Recreational Water*
Source Type: *Spa*

Sample Collection

Date: *7/22/25*
Time: *9:45 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/25/25*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	11:00 AM	AH
Total coliforms:	0/100mls	2/100mls	7/23/25	11:00 AM	AH
Standard plate count:	0/ml	200/ml	7/22/25	5:00 PM	SL

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/23/25	12:20 PM	SL

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/22/25	9:45 AM	LM
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/22/25	9:45 AM	LM
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	9:45 AM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 117

Customer

Facility Name: *Hampton Inn*
Address: *1247 Smallman St.
Pittsburgh, PA 15222*
Matrix: *Recreational Water*
Source Type: *Spa*

Sample Collection

Date: *7/22/25*
Time: *9:45 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/25/25*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	11:00 AM	AH
Total coliforms:	0/100mls	2/100mls	7/23/25	11:00 AM	AH
Standard plate count:	0/ml	200/ml	7/22/25	5:00 PM	SL

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/23/25	12:20 PM	SL

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/22/25	9:45 AM	LM
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/22/25	9:45 AM	LM
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	9:45 AM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor