



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-10**

**Lab# 366**

**Customer**

Facility Name: YMCA - Thelma Lovette

Address: 2114 Centre Ave.  
Pittsburgh, PA 15219

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 5/27/25

Time: 1:35 PM

Method: Grab

**Sample Final Analysis**

Date: 5/30/25

Time: 9:00 AM

Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 5/28/25 9:45 AM      | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 5/28/25 9:45 AM      | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 5/27/25 4:20 PM      | EB      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time       | Analyst | Method |
|----------------|----------|-----------------|-----------------|---------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | 5/27/25 1:35 PM | LM      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 5/27/25 1:35 PM | LM      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 5/27/25 1:35 PM | LM      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-10**

**Lab# 366**

**Customer**

Facility Name: YMCA - Thelma Lovette

Address: 2114 Centre Ave.  
Pittsburgh, PA 15219

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 5/27/25

Time: 1:35 PM

Method: Grab

**Sample Final Analysis**

Date: 5/30/25

Time: 9:00 AM

Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 5/28/25 9:45 AM      | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 5/28/25 9:45 AM      | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 5/27/25 4:20 PM      | EB      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time       | Analyst | Method |
|----------------|----------|-----------------|-----------------|---------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | 5/27/25 1:35 PM | LM      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 5/27/25 1:35 PM | LM      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 5/27/25 1:35 PM | LM      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor