

## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2005

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Accord -Avonworth

Address: 498 Camp Horne Road

Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 6/23/25

Time: 12:21 PM Method: Grab

Sample Final Analysis

 Date:
 6/26/25

 Time:
 9:00 AM

 Analyst:
 AS

August Mathad

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	10:40 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	10:40 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	5:20 PM	EB	SM 9215B
Field Analysis	Results	Reporting limit	Ī	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/23/25	12:21 PM	MM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/23/25	12:21 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	12:21 PM	ММ	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2005

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Accord -Avonworth

Address: 498 Camp Horne Road

Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 6/23/25

Time: 12:21 PM Method: Grab

Sample Final Analysis

 Date:
 6/26/25

 Time:
 9:00 AM

 Analyst:
 AS

August Mathad

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	10:40 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	10:40 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	5:20 PM	EB	SM 9215B
Field Analysis	Results	Reporting limit	Ī	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/23/25	12:21 PM	MM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/23/25	12:21 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	12:21 PM	ММ	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor