



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2020

Customer

Facility Name: Apts of Cedar Ridge

Address: 250 Cedar Ridge Dr.
Monroeville, PA 15146

Sample Collection

Date: 8/11/25
Time: 7:28 AM
Method: Grab

Matrix: Recreational Water

Source Type: Pool

Sample Final Analysis

Date: 8/14/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	2:31 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/11/25	7:28 AM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/11/25	7:28 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	7:28 AM	EH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2020

Customer

Facility Name: Apts of Cedar Ridge

Address: 250 Cedar Ridge Dr.
Monroeville, PA 15146

Sample Collection

Date: 8/11/25
Time: 7:28 AM
Method: Grab

Matrix: Recreational Water

Source Type: Pool

Sample Final Analysis

Date: 8/14/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	2:31 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/11/25	7:28 AM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/11/25	7:28 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	7:28 AM	EH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor