



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2645

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

		<u>Sample Collection</u>	
Facility Name:	Pennwood Square	Date:	6/9/25
Address:	601 A Hay St Pittsburgh, PA 15221	Time:	1:42 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		

	<u>Sample Final Analysis</u>		
Matrix:	Recreational Water	Date:	6/12/25
Source Type:	Pool	Time:	9:30 AM
		Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/10/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	2:51 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	6/9/25	1:42 PM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/9/25	1:42 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	1:42 PM	EH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2645

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

		<u>Sample Collection</u>	
Facility Name:	Pennwood Square	Date:	6/9/25
Address:	601 A Hay St Pittsburgh, PA 15221	Time:	1:42 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		

	<u>Sample Final Analysis</u>		
Matrix:	Recreational Water	Date:	6/12/25
Source Type:	Pool	Time:	9:30 AM
		Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/10/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	2:51 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	6/9/25	1:42 PM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/9/25	1:42 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	1:42 PM	EH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor