



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

W-10

Lab# 2744

**Customer**

Facility Name: Seven Oaks C.C.

**Sample Collection**

Date: 6/16/25

Address: 132 Lisbon Road  
Beaver, PA 15009

Time: 2:28 PM

Method: Grab

Matrix: Recreational Water

**Sample Final Analysis**

Date: 6/19/25

Source Type: Adult Pool

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/17/25	12:00 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	12:00 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	6/16/25	2:28 PM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/16/25	2:28 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	2:28 PM	AH	Visual

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

W-10

Lab# 2744

**Customer**

Facility Name: Seven Oaks C.C.

**Sample Collection**

Date: 6/16/25

Address: 132 Lisbon Road  
Beaver, PA 15009

Time: 2:28 PM

Method: Grab

Matrix: Recreational Water

**Sample Final Analysis**

Date: 6/19/25

Source Type: Adult Pool

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/17/25	12:00 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	12:00 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	6/16/25	2:28 PM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/16/25	2:28 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	2:28 PM	AH	Visual

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor