



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2284

Customer

Facility Name: *Independence Square*

Address: *Lexington Dr*
Aliquippa, PA 15001

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *8/4/25*

Time: *10:36 AM*

Method: *Grab*

Sample Final Analysis

Date: *8/7/25*

Time: *11:20 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	1:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	1:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	7:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/4/25	10:36 AM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/4/25	10:36 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	10:36 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2284

Customer

Facility Name: Independence Square

Address: Lexington Dr
Aliquippa, PA 15001

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/4/25

Time: 10:36 AM

Method: Grab

Sample Final Analysis

Date: 8/7/25

Time: 11:20 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25 1:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25 1:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25 7:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/4/25 10:36 AM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/4/25 10:36 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25 10:36 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor