

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 E-14

Lab# 478

<u>Customer</u> <u>Sample Collection</u>

200/ml

Facility Name: Comfort Inn Duncansville Date: 5/27/25
Time: 12:00 AM
Address: 130 Patchway Rd. Method: Grab

130 Patchway Rd. Method: Duncansville, PA 16635

Matrix: Recreational Water Sample Final Analysis

Date: 5/30/25

Source Type: Spa Time: 9:00 AM
Analyst: AS

Accredited Analysis Results Reporting limit Incubation Date/Time Analyst Method

Escherichia Coli: Absent Absent 5/28/25 10:15 AM EB SM 9222G

Total coliforms: 0/100mls 2/100mls 5/28/25 10:15 AM EB SM 9222B

5/27/25

Additional Analysis Results Reporting limit Incubation Date/Time Analyst Method

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	5/27/25	12:40 PM	DP	DPD	
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	5/27/25	12:40 PM	DP	DPD	
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	12:40 PM	DP	Visual	

Sample comments

Standard plate count:

0/ml

(When exceeding reporting limit pool or spa is unfit)

andre Smith

5:40 PM

AS

SM 9215B

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 E-14

Lab# 478

<u>Customer</u> <u>Sample Collection</u>

200/ml

Facility Name: Comfort Inn Duncansville Date: 5/27/25
Time: 12:00 AM
Address: 130 Patchway Rd. Method: Grab

130 Patchway Rd. Method: Duncansville, PA 16635

Matrix: Recreational Water Sample Final Analysis

Date: 5/30/25

Source Type: Spa Time: 9:00 AM
Analyst: AS

Accredited Analysis Results Reporting limit Incubation Date/Time Analyst Method

Escherichia Coli: Absent Absent 5/28/25 10:15 AM EB SM 9222G

Total coliforms: 0/100mls 2/100mls 5/28/25 10:15 AM EB SM 9222B

5/27/25

Additional Analysis Results Reporting limit Incubation Date/Time Analyst Method

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	5/27/25	12:40 PM	DP	DPD	
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	5/27/25	12:40 PM	DP	DPD	
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	12:40 PM	DP	Visual	

Sample comments

Standard plate count:

0/ml

(When exceeding reporting limit pool or spa is unfit)

andre Smith

5:40 PM

AS

SM 9215B

Andre Smith, Lead Supervisor