



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 436

Customer

Facility Name: Grove City College
Address: 100 Campus Dr.
Grove City, PA 16127
Matrix: Recreational Water
Source Type: Comp Pool

Sample Collection

Date: 11/24/25
Time: 1:55 PM
Method: Grab

Sample Final Analysis

Date: 11/27/25
Time: 12:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	11/25/25	12:00 PM	AS SM 9222G
Total coliforms:	0/100mls	2/100mls	11/25/25	12:00 PM	AS SM 9222B
Standard plate count:	0/ml	200/ml	11/24/25	5:40 PM	AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	11/24/25	1:55 PM	BH DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	11/24/25	1:55 PM	BH DPD
Turbidity:	1 NTU	1 - 2 NTU	11/24/25	1:55 PM	BH Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor